

ADDENDUM NUMBER 01
TO THE PLANS AND SPECIFICATIONS FOR:
The Newport Library Garages
08 October 2019

TO ALL BIDDERS:

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become part of the contract documents.

General Information

1. The period for inquiries expired at Noon October 8, 2019. As such, no further inquiries will be addressed nor will any addenda be issued after Addendum #2.

Drawings and Specifications

1. Regarding patching operations required of existing asphalt paving that is disturbed during construction:
 - a. The PLYMC acknowledges that due to the late seasonal start, the asphalt paving work can be deferred until Spring 2020 if required. Contractors shall patch the pavement at the earliest opportunity presented in the spring.
 - b. In the event that asphalt paving is deferred, the contract with the builder will be kept open by holding some of the retainage funds until the work is suitably complete.
2. The CO/NO2 shall be Brasch BGM-NCM-TRNS as specified on Sheet M-1.
3. The current Fire Alarm System is a GE/Edwards System Technology.



FANIRO ARCHITECTS, INC.

217 ½ WEST FEDERAL STREET
TELEPHONE: 330.747.2800

YOUNGSTOWN, OHIO 44503
FACSIMILE: 330.747.2802